

Demko Certificate

Product: Conduit for electrical installations
Manufacturer: P.M. S.R.L.
Plastic Materials, Via Garibaldi 44, IT-24031 Almenno S Salvatore (BG), ITALY
Production site: P.M. S.R.L.
Plastic Materials, Via Garibaldi 44, IT-24031 Almenno S Salvatore (BG), ITALY
Certified by request of: P.M. S.R.L.
Plastic Materials, Via Garibaldi 44, IT-24031 Almenno S Salvatore (BG), ITALY
Trademark: -
Model/Type ref.: See appendix.
Rated current or power: -
Rated voltage: -
Insulation Class: -
Degree of protection: -
Additional information: See appendix.

Variants covered by this certificate are specified in the attached appendix.
Detailed specification of the certified product(s) is listed in the appendix.

A sample of the product has been tested and found in conformity with EN 61386-1:2004 and EN 61386-22:2004.

Date of expiry: 2012-11-23.

Furthermore, the product complies with the national deviations in Denmark.

UL International Demko AIS is a body notified to the Member States and Commission of the European Communities according to the provisions of Article 8 of the Low Voltage Directive.

The Manufacturer complies with the Production Surveillance Requirements. Products included in this certificate are allowed to carry the registered approval marks of UL International Demko AIS, or for cables <DEMKO>. The name of UL International Demko AIS can be used in the marketing of the products. This Statement is only valid for products, which are identical to the tested product, and manufactured at the above-mentioned production site(s). UL International Demko AIS has to be informed in writing about any changes, in accordance with the "UL International Demko AIS Standard Terms and Conditions" for UL International Demko AIS services. The validity of this certificate is shortened if the EU legislation requires re-testing and re-certification, due to new standards or amendments coming into force, before the expiry date.

Herlev, 2008-05-27


Jan-Erik Storgaard
Certification Manager

UL International Demko A/S

Lyskaer 8, P.O. Box 514
DK-2730 Herlev, Denmark
Telephone: +45 44856565
Fax: +45 44856500



An Affiliate of
**Underwriters
Laboratories Inc.®**

Appendix to Demko Certificate No. 314624-01

The Certificate covers the following:
Additional information:

01; ICE 16; Pliable conduit of insulated material in grey and ivory colour. Size 16mm.
Temperature range -25/+60°C. Non-flame propagating. Classification 3341.

02; ICE 20; Pliable conduit of insulated material in grey and ivory colour. Size 20mm.
Temperature range -25/+60°C. Non-flame propagating. Classification 3341.

03; ICE 25; Pliable conduit of insulated material in grey and ivory colour. Size 25mm.
Temperature range -25/+60°C. Non-flame propagating. Classification 3341.

04; ICE 32; Pliable conduit of insulated material in grey and ivory colour. Size 32mm.
Temperature range -25/+60°C. Non-flame propagating. Classification 3341.

05; ICE 40; Pliable conduit of insulated material in grey and ivory colour. Size 40mm.
Temperature range -25/+60°C. Non-flame propagating. Classification 3341.

06; ICE 50; Pliable conduit of insulated material in grey and ivory colour. Size 50mm.
Temperature range -25/+60°C. Non-flame propagating. Classification 3341.

The certificate has been issued on the basis of Nordic certification Service, certificate No. 802999,
issued by Intertek ETL SEMKO, dated 2008.04.21.

Herlev, 2008-05-27


Jan-Erik Storgaard
Certification Manager

UL International Demko A/S

Lyskaer 8, P.O. Box 514
DK-2730 Herlev, Denmark
Telephone: +45 44856565
Fax: +45 44856500



An Affiliate of
**Underwriters
Laboratories Inc.®**