

Demko Certificate

Product: Conduit for electrical installations
Manufacturer: P.M. S.R.L.
Plastic Materials, Via Garibaldi 44, IT-24031 Almenno S Salvatore (BG), ITALY
Production site: P.M. Plastic Materials SRL
24030 Almenno San Bartolomeo (BG), ITALY
Certified by request of: P.M. S.R.L.
Plastic Materials, Via Garibaldi 44, IT-24031 Almenno S Salvatore (BG), ITALY
Trademark: -
Model/Type ref.: See appendix.
Rated current or power: -
Rated voltage: -
Insulation Class: -
Degree of protection: -
Additional information: No halogen according to EN 50267-2-1:1999 and EN 50267-2-2:1999.
The conduits comply with requirement according Low Smoke "LSZH" test to IEC 61034-2:1997.

Variants covered by this certificate are specified in the attached appendix.
Detailed specification of the certified product(s) is listed in the appendix.

A sample of the product has been tested and found in conformity with EN 61386-1:2004 and EN 61386-22:2004.

Date of expiry: 2012-11-23.

Furthermore, the product complies with the national deviations in Denmark.

UL International Demko A/S is a body notified to the Member States and Commission of the European Communities according to the provisions of Article 8 of the Low Voltage Directive.

The Manufacturer complies with the Production Surveillance Requirements. Products included in this certificate are allowed to carry the registered approval marks of UL International Demko A/S, or for cables <DEMKO>. The name of UL International Demko A/S can be used in the marketing of the products. This Statement is only valid for products, which are identical to the tested product, and manufactured at the above-mentioned production site(s). UL International Demko A/S has to be informed in writing about any changes, in accordance with the "UL International Demko A/S Standard Terms and Conditions" for UL International Demko A/S services. The validity of this certificate is shortened if the EU legislation requires re-testing and re-certification, due to new standards or amendments coming into force, before the expiry date.

Herlev, 2008-05-27


Jan-Erik Storgaard
Certification Manager

UL International Demko A/S

Lyskaer 8, P.O. Box 514
DK-2730 Herlev, Denmark
Telephone: +45 44856565
Fax: +45 44856500



An Affiliate of
**Underwriters
Laboratories Inc.®**

Appendix to Demko Certificate No. 314627-01

The Certificate covers the following:

01; ICTA 16; Pliable self-recovering conduit of insulated material in ivory, green, black, grey and blue colour. Size 16 mm. Temperature range $-5/+90^{\circ}\text{C}$. Non-flame propagating. Classification 3422.

02; ICTA 20; Pliable self-recovering conduit of insulated material in ivory, green, black, grey and blue colour. Size 20 mm. Temperature range $-5/+90^{\circ}\text{C}$. Non-flame propagating. Classification 3422.

03; ICTA 25; Pliable self-recovering conduit of insulated material in ivory, green, black, grey and blue colour. Size 25 mm. Temperature range $-5/+90^{\circ}\text{C}$. Non-flame propagating. Classification 3422.

04; ICTA 32; Pliable self-recovering conduit of insulated material in ivory, green, black, grey and blue colour. Size 32 mm. Temperature range $-5/+90^{\circ}\text{C}$. Non-flame propagating. Classification 3422.

05; ICTA 40; Pliable self-recovering conduit of insulated material in ivory, green, black, grey and blue colour. Size 40 mm. Temperature range $-5/+90^{\circ}\text{C}$. Non-flame propagating. Classification 3422.

06; ICTA 50; Pliable self-recovering conduit of insulated material in ivory, green, black, grey and blue colour. Size 50 mm. Temperature range $-5/+90^{\circ}\text{C}$. Non-flame propagating. Classification 3422.

07; ICTA 16; Pliable self-recovering conduit of insulated material in ivory, green, black, grey and blue colour. Size 16 mm. Temperature range $-25/+90^{\circ}\text{C}$. Non-flame propagating. Classification 3342.

08; ICTA 20; Pliable self-recovering conduit of insulated material in ivory, green, black, grey and blue colour. Size 20 mm. Temperature range $-25/+90^{\circ}\text{C}$. Non-flame propagating. Classification 3342.

09; ICTA 25; Pliable self-recovering conduit of insulated material in ivory, green, black, grey and blue colour. Size 25 mm. Temperature range $-25/+90^{\circ}\text{C}$. Non-flame propagating. Classification 3342.

10; ICTA 32; Pliable self-recovering conduit of insulated material in ivory, green, black, grey and blue colour. Size 32 mm. Temperature range $-25/+90^{\circ}\text{C}$. Non-flame propagating. Classification 3342.

11; ICTA 40; Pliable self-recovering conduit of insulated material in ivory, green, black, grey and blue colour. Size 40 mm. Temperature range $-25/+90^{\circ}\text{C}$. Non-flame propagating. Classification 3342.

12; ICTA 50; Pliable self-recovering conduit of insulated material in ivory, green, black, grey and blue colour. Size 50 mm. Temperature range $-25/+90^{\circ}\text{C}$. Non-flame propagating. Classification 3342.

Herlev, 2008-05-27


Jan-Erik Storgaard
Certification Manager

UL International Demko A/S

Lyskaer 8, P.O. Box 514
DK-2730 Herlev, Denmark
Telephone: +45 44856565
Fax: +45 44856500



An Affiliate of
**Underwriters
Laboratories Inc.®**

Appendix to Demko Certificate No. 314627-01

This certificate replaces the certificate No. 313553-01, dated 2005-08-29.
UL International Demko A/S has issued a new certificate due to new standards.

The certificate has been issued on the basis of Nordic certification Service, certificate No. 802997,
issued by Intertek ETL SEMKO, dated 2008-04-29.

Herlev, 2008-05-27


Jan-Erik Storgaard
Certification Manager

UL International Demko A/S

Lyskaer 8, P.O. Box 514
DK-2730 Herlev, Denmark
Telephone: +45 44856565
Fax: +45 44856500



An Affiliate of
**Underwriters
Laboratories Inc.®**